



No. 33332077-1E

CERTIFICATE CERTIFICADO CERTIFICATE CERTIFICADO CERTIFICADO



**TÜVRheinland**

**CERTIFICATE**

Holder of Certificate	<b>MANUSA DOOR SYSTEMS SLU</b> Av. Via Augusta, 85-87, 6º 08174 – Sant Cugat del Vallès (Bcn) SPAIN
Product	Operator to Powered Pedestrian Doors
Models	VISIO VISIO 100 VISIO HERMÉTICO
According to	EN 16005 EN – ISO 13849-1/2. <b>PL "d"</b> EN 60335-1 IEC / EN 60335-2-103 EN 61000-6-2 / 6-3 / 3-2 / 3-3 EN – ISO 12100 UNE 85121 EX
Parameters	Endurance    2.500.000 cycles Tª Service    -15°C a +50°C Voltage        220-240 V / 50-60 Hz Power supply    VISIO: 265W VISIO 100: 95W VISIO HERMÉTICO: 265 W

The product has been tested on a voluntary basis and is subject to regulatory requirements referenced.  
Date: 2014-11-28



Carlos Moragrega Garcia  
Technical Inspector  
Technical Industrial Engineer